
Addendum No. 3 Acequias de Chamisal y Ojito Pipeline Project

The purpose of this Addendum No. 3 is to respond to questions submitted by potential bidders for construction of the Acequias de Chamisal y Ojito Pipeline Project.

1. Response to questions are provided in UPPER CASE FONT:

Is the Pollution Control (Line Item 2 on Base Bid) meant to be used for SWPPP?
If not, is SWPPP required for the project?

A SWPPP IS NOT REQUIRED. CONTRACTOR SHALL COMPLY WITH THE PROVISIONS OF SPECIFICATION NO. 2 – POLLUTION CONTROL.

Is surveying of the pipe alignment and surveyed as-builts both required? or just one or the other?

CONTRACTOR SHALL SURVEY THE ALIGNMENT AND MAINTAIN PIPELINE GRADE FOR CONSTRUCTION. AS-BUILT SURVEY IS NOT REQUIRED.

Is onsite material available for the 50 CY of pipe bedding (line item 6 of the base bid) or will imported material be required?

BEDDING MATERIAL IS AVAILABLE ON SITE FROM THE LOCATION VISITED DURING THE NOVEMBER 15, 2024, PRE-BID MEETING. SORTING AND PROCESSING MAY BE REQUIRED TO MEET THE PROVISIONS OF SPECIFICATION 45-4.

Is onsite material available for the 470 CY of compacted backfill (line item 7 of the base bid) or will imported material be required?

FILL MATERIAL IS AVAILABLE ON SITE. NO IMPORTATION OF MATERIAL FROM OFF SITE IS REQUIRED.

Is a Staging Area available within the project site?

AREAS FOR STORAGE OF MATERIAL AND STAGING OF CONSTRUCTION ACTIVITY IS AVAILABLE ADJACENT TO THE ACEQUIA ALIGNMENT.

Will compaction density testing be required? If so, will an allowance line item be included for Material Testing?

DENSITY TESTING IS NOT REQUIRED. CONTRACTOR IS RESPONSIBLE FOR COMPLYING WITH THE PROVISIONS OF SPECIFICATION 23.6 AND SPECIFICATION 45.5.

2. Bids are due at 5:00 pm on November 21, 2024.
3. Bids may be submitted electronically via email to construct@wjmillereengineers.com. Bids must be compiled into a single pdf document. Bid bonds, if in the form of a certified check, must be submitted via U. S. mail or hand delivered. No copies of checks will be accepted.
4. All other provisions of the July 1, 2021, Contract Documents remain unchanged.